

To: Mayor and Members of Council

June 27, 2011

Re: Foreman's Report

Equipment:

The Town ordered a finishing mower. It should arrive the first week of July.

The lagoon pivot is working well. No issues at this time. The lagoon level is at 50%.

The new skidsteer is on back order due to the Japanese tsunami/earthquake. Engines for the skidsteers are made in Japan. Projected arrival is the end of June.

A pump was rented to remove excess water from Ramm Avenue East to Highway 48.

Road Repair:

I am in the process of getting quotes to repair Lott Road and White City Drive.

Water Treatment Plant:

There are additional costs to replace check valves. Further investigation indicated that there is another option to repair. Instead of stainless steel piping, the Town will approve scheduled 80 plastic pipe at a less expensive cost.

Ball Field:

Sprinkler system is in place to irrigate the sodded ball diamond. I am waiting for further information for light installation. Test run was conducted on the irrigation and it appears to be operating well.

Lift Stations:

Due to the high levels of rain, the lift stations are having a hard time keeping up with the grey water because of the amount of ground water being pumped into the sewer system by citizens from their sump pumps. It is against the bylaw to pump ground water into the sewer system. If this continues, we will have some homes flooded with sewage. The Number One Lift Station cannot keep up with the high volume of grey water. I suggest an engineer look at the Number One Lift Station to give direction on how to rectify the problem.

Respectfully submitted,

Darryle Bulych